

FIRE

कार्यालय सहायक मण्डल अग्नि शमन अधिकारी दमकल केन्द्र सैक्टर-25 फरीदाबाद

प्रेषक:-

दमकल केन्द्र अधिकारी,
सैक्टर-25, फरीदाबाद।

सेवा में:-

Principal,
Aksharam School run by Parmar Educational & Cultural Society,
PA Block, Parklands Pride, Sector-77, Faridabad

क्रमांक: FSO/2025/992

दिनांक : 02/07/2025

विषय:-

Request to add School Name "Aksharam School" to Fire Safety Certificate-
Regarding Educational Building at PA Block, Parklands Pride Sector-77,
Faridabad.

उपरोक्त विषय के सन्दर्भ में।

विषयाधीन मामले में अनुरोध के साथ अवगत कराया जाता है कि "Aksharam School", PA Block, Parklands Pride Sector-77, Faridabad M/s Parmar Educational & Cultural Society के द्वारा उपरोक्त पते पर चलाया जा रहा है। जिसका अन्नापत्ति प्रमाण पत्र Memo no. FS/2024/408 Dated 03/04/2024 को 3 वर्ष के लिए जारी किया गया है।

[Signature]
02/07/25
दमकल केन्द्र अधिकारी,
सैक्टर-25, फरीदाबाद।

[Signature]
AKSHARAM SCHOOL
PA Block, BPTP Parkland Pride
Sector-77, Faridabad-121002

From Director General
Fire Service, Haryana Panchkula

To M/s PARMAR EDUCATION AND CULTURAL SOCIETY
PA BLOCK SECTOR 77 FARIDABAD HARYANA
Memo No. FS/2024/408 dated : 03/04/2024

Subject : Fire Safety Certificate 15 mtrs. and Above from the fire safety point of view for Group B- Educational Building at PA BLOCK SECTOR 77 FARIDABAD HARYANA of PARMAR EDUCATION AND CULTURAL SOCIETY :

Reference your letter no. 030152423000155 dated 04/03/2024 on the subject cited above.

Tower Name	Floor Detail	Height	Ground Coverage
Educational Building	G+2	13.50 mtr.	1203.105 Sq. mtr.
Tower Name	Basement Level	Basement Area	Basement Remarks
	Basement-1	594.166	Parking
	Basement-2	883.522	Parking

- 1) The owner/occupier shall give a self declaration certificate annually regarding fire safety system installed in his building/premises is working in good condition and there is no addition/alteration in the building.
- 2) In case there is any addition/alteration in the building, the Fire Safety Certificate shall cease to exist and the owner shall apply for approval of revised Fire Fighting Scheme
- 3) As per sub-section (1) and the competent authority may randomly check such building/premises.
- 4) The owner/occupier shall keep duly trained Fire Staff in all three shifts.
- 5) The Fire Protection System tested during inspection shall be maintained properly & always should be in good working condition.
- 6) If any lapse is found in the fire protection system at the time of inspection or detected during outbreak of fire, action will be taken as per rules against you.
- 7) You are directed to apply for Fire Safety Certificate in future before 2 months of expiry of your Fire Safety Certificate.
- 8) The open set back area is not checked at our end as it shall be checked by concerned building authority/department.
- 9) The owner/occupier shall strictly follow the other applicable rules/ regulations/ byelaws laid down regarding fire safety system. If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Section 30.31 & 47 of Fire & Emergency Services Act 2022.
- 10) You have to perform quarterly Fire Drill in your building as per NBC with intimation to Fire Department and video graphy evidence to be kept as a record which shall be produced at the time of next Renewal; Official/Staff should be participated in the drill.
- 11) If the Infringements of Byelaws remains un-noticed the Authority reserves the right to amend the Fire Safety Certificate as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 12) Fire safety Certificate granted subject to condition that there is no violation in sanctioned building plan by virtue of which fire fighting scheme was approved.
- 13) The owner or occupier of the building shall give a self-declaration certificate annually to the effect that the fire fighting system installed in his building is working in good condition and there is no addition/alteration in the building. The Fire Officer may randomly check such building. In case there is any addition/alteration beyond permissible limits under the Haryana Building Code, 2017, the fire safety certificate shall cease to exist and the owner shall apply for approval of revised Fire Fighting Scheme as per the provisions of section 18.

The above Fire Safety Certificate is valid for only **Three** year from the date of issue of this letter Applying renewal of the same well in time shall be the responsibility of owner/occupier.

Remarks:- ok



Handwritten signature and stamp of the Deputy Director (Technical)-I, Fire Service, Haryana Panchkula. The stamp includes the text: 'PA BLOCK SECTOR 77 FARIDABAD HARYANA' and 'Date: 12/04/2024'.

Deputy Director (Technical)-I,
Fire Service, Haryana Panchkula
Digitally signed by G. S. SHAN
Date: 2024.04.03 15:34:26 +05:30
Reason: Digital Verification

Exercising the power of Director, Fire Services, Haryana